

SOIL CONTROL LAB

42 HANGAR WAY
WATSONVILLE
CALIFORNIA
95076
USA

RFV

Pajaro/ Sunny Mesa CSD I
136 San Juan Road
Royal Oaks, CA 95076
Attn: Don Rosa

Work Order #: 3030614
Reporting Date: March 30, 2023

Bacteriological Examination of Water for Coliform Organisms

Date Received: Water sample(s) received March 29, 2023
Project # / Name: None / None
Water System #/Name: CA2710020
Sampling Type: Special Sampling Period: Mar 2023
Sampler's Name: Rafael Farfan / Pajaro Sunny Mesa
Matrix: Drinking Water

<u>Sample Identification</u>	<u>Sampling Date</u>	<u>Sampling Time</u>	<u>Residual Chlorine (mg/L)</u>	<u>Total Coliforms</u>	<u>E. coli</u>
Pajaro Well #2	03/29/23	07:38	ND	Absent	Absent

(2)

Date/Time Analyzed: 03/29/23 16:52
Method of Analysis: SM 9223 B

CA ELAP Certificate #1494 (This identifies our Laboratory to the Health Department)

cc. SWRCB-DDW-05

Mike Galloway