



MBAS

Monterey Bay Analytical Services

4 Justin Court Suite D, Monterey, CA 93940

831.375.MBAS (6227)

www.MBASinc.com

ELAP Certification Number: 2385

Friday, March 24, 2023

Pajaro Sunny Mesa Svc District

Don Rosa

136 San Juan Road

Royal Oaks, CA 95076

Sample Results

Lab Number: 230323_66-01

Collection Date/Time: 3/23/2023 10:43

Sample Collector: Farfan R

Client Sample #:

Received Date/Time: 3/23/2023 16:00

System ID: CA2700773_NR

Coliform Designation: Special

Sample Description: Sunny Mesa WS, Sunny Mesa Well #2

Analyte	Method	Unit	Result	Qualifier	Dilution	PQL	Analysis Date/Time	Analyst
Chlorine Residual (Field)	External	mg/L	ND		1		3/23/2023 10:43	
Coliform, E Coli	SM9223B-18hr	/100mL	Absent		1		3/23/2023 16:30	SB
Coliform, Total	SM9223B-18hr	/100mL	Absent		1		3/23/2023 16:30	SB

Comments:

Lab Number: 230323_66-02

Collection Date/Time: 3/23/2023 11:04

Sample Collector: Farfan R

Client Sample #:

Received Date/Time: 3/23/2023 16:00

System ID: CA2700773_NR

Coliform Designation: Special

Sample Description: Sunny Mesa WS, Sunny Mesa Well #2

Analyte	Method	Unit	Result	Qualifier	Dilution	PQL	Analysis Date/Time	Analyst
Chlorine Residual (Field)	External	mg/L	ND		1		3/23/2023 11:04	
Coliform, E Coli	SM9223B-18hr	/100mL	Absent		1		3/23/2023 16:30	SB
Coliform, Total	SM9223B-18hr	/100mL	Absent		1		3/23/2023 16:30	SB

Comments:

Report Approved by:


David Holland, Laboratory Director

The results in this report are related only to the samples analyzed.

This certificate of analysis shall not be reproduced except in full, without written approval of the laboratory.

(V)

Abbreviations/Definitions:
 mg/L: Milligrams per liter (=ppm)
 MDL: Method Detection Limit
 E: Analysis performed by External Laboratory; see Report attachments
 J: Result is < PQL but ≥ MDL; the concentration is an approximate value.

µg/L: Micrograms per liter (=ppb)
 MCL: Maximum Contamination Level
 H: Analyzed outside of method hold time

MPN: Most Probable Number
 ND: Not Detected at the PQL (or MDL, if shown)
 QC: Quality Control