

# SOIL CONTROL LAB

42 HANGAR WAY  
WATSONVILLE  
CALIFORNIA  
95076  
USA

*RFV*

Pajaro/ Sunny Mesa CSD I  
136 San Juan Road  
Royal Oaks, CA 95076  
Attn: Don Rosa

Work Order #: 3030596  
Reporting Date: March 29, 2023

## Bacteriological Examination of Water for Coliform Organisms

Date Received: Water sample(s) received March 28, 2023  
Project # / Name: None / None  
Water System #/Name: CA2710020  
Sampling Type: Special Sampling Period: Mar 2023  
Sampler's Name: Rafael Farfan / Pajaro Sunny Mesa  
Matrix: Drinking Water

<u>Sample Identification</u>	<u>Sampling Date</u>	<u>Sampling Time</u>	<u>Residual Chlorine (mg/L)</u>	<u>Total Coliforms</u>	<u>E. coli</u>
Pajaro Well #2	03/28/23	08:05	ND	Absent	Absent

(L)

Date/Time Analyzed: 03/28/23 16:51  
Method of Analysis: SM 9223 B

CA ELAP Certificate #1494 (This identifies our Laboratory to the Health Department)

cc. SWRCB-DDW-05

*Mike Galloway*